

**Water Division  
Status Report  
01/02/2019 – 01/08/2019**

**Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:**

- 208 Princeton Avenue
- Spindles Way
- 14 Cedar Drive
- 115-119 Ft Dix (Emergency)
- 3401 Liberty Street
- Duncan Street
- Mockingbird Lane
- 114 Sepulga Drive
- 25 Ridge Road
- Clematis Street
- 237 Rutgers Avenue

**Water Meters:**

- Completed meter readings in Books 7, 8 & 8A (South Lakeshore)
- Continued meter readings in Books 9 & 10 (North Lakeshore)
- Final readings: 448 Cornell Avenue 4 Morton Road  
318 University Avenue
- Read meters at Lakeshore Mobile Village and Pemberton Boro
- Replaced meter at 72 Columbus Avenue and 501 Junction Road

**Water Turn Off/Turn On:**

- Turned off 30 Sussex Street - Leak

**Water Wells:**

- Daily routine well checks morning/afternoon
- Replenished chemical supplies as needed
- Water samples
- Adjusted chlorine at County wells
- Removed downed tree from fence at Well #6
- Adjusted chlorine residual at county system

**Miscellaneous:**

- Repaired chlorine shed
- Investigated leak by water shop
- Flushed fire hydrant on Brooke Street
- Charged battery and inflated tires on pipe forklift
- Installed sump pump at water shop
- Fueled trucks
- Greased and performed maintenance on backhoe
- Made copies of keys
- Repaired and performed maintenance on mud pump
- Repaired leak at 115 Fort Dix Road
- Hauled scrap metal to Red Lion
- Insulated, shut off and removed meters from empty units in the Browns Mills Shopping Ctr