

**Water Division  
Status Report  
01/09/2019 – 01/15/2019**

**Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:**

- 522 Berkeley Drive
- 4202 S. Lakeshore Drive
- 611 Cabot Drive
- 37 Pemberton Vincentown Rd
- 25 Ridge Road
- Spruce Blvd (Emergency)
- 232 Park Street
- 45 Eldridge Street
- 71 Sepulga Drive
- 302 Lakeview Blvd
- 390 Lakehurst Road
- 500 PBM Road
- 238 Delmar Avenue
- Learning Way
- 527 Larch Avenue
- Princess Street
- 75 Clubhouse Road
- 119 Apple Avenue
- 236 Delmar Avenue
- 200 Trenton Road

**Water Meters:**

- Completed meter readings in Books 9 & 10 (North Lakeshore)
- Continued meter readings in Books 11 & 12 (North Lakeshore/Browns Mills)
- Final readings:           39 Filbert Avenue           161 Juliustown Road           13 Kent Street
- Replaced meters:       301 Arrahbella Avenue   519 Ridgeview Avenue
- Re-read 146 Dennis Avenue to confirm quarterly reading

**Water Turn Off/Turn On:**

- Turned on 301 Arrahbella Avenue
- Turned off 701 Hunter Blvd
- Turned on Unit Q at the Browns Mills Shopping Center
- Turned off 10 Wildgeese Circle

**Water Wells:**

- Daily routine well checks morning/afternoon
- Replenished chemical supplies as needed
- Water samples
- Repaired exhaust fan and replaced chlorine supply line at Well #11
- Assisted with sample bottles
- Repaired chlorine line at Well #1
- Well #2 valve for point of entry sample
- Repaired sump pump at County Well #10

**Miscellaneous:**

- Checked complaint of possible leak on West Lakeshore Drive
- Re-stocked and arranged meter shelf
- Prepared trucks for snow: fueled and attached snow plows
- Assisted plumber at 378 Lakehurst Road
- Repaired leak at 524 Lakehurst Road. Cleaned up and patched.
- Repaired plate tamper
- Flushed hydrant on Heather Street
- Replaced meter at 435 Garden Avenue