

**Water Division
Status Report
01/30/2019 – 02/05/2019**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- 435 Dartmouth Avenue
- 134 Vance Street
- 15 Juliustown Road
- 24 Dahlia Street
- 109 Tensaw Drive
- North Pemberton Road
- 3 Lobelia Avenue
- 3-7 Talledega Trail

Water Meters:

- Completed meter readings in Books 15 & 16 (Browns Mills)
- Continued meter readings in Books 17 & 18 (Boro and Country Lakes)
- Final readings: 10 Canna Street 302 High Street 108 Scammel Drive

Water Turn Ons/Turn Offs:

- Turned on 701 Hunter Blvd
- Turned off 115 Hanover Blvd
- Turned off 801 Hanover Blvd
- Turned off 20 Bella Coola Trail
- Turned off 65 Columbus Avenue

Water Wells:

- Daily routine well checks morning/afternoon
- Replenished chemical supplies as needed
- Water samples
- Salted sidewalks at Well #1
- Checked all well and tank heaters
- Re-installed ladder hatch at Beech Street
- Uni-Tech Well Drillers – set meter at Well #7
- Thawed out lines at Well #7
- Met with JCP&L for power issues at Well #7
- Repaired chlorine lines at Well #7
- Checked Well #6 and Well #12 tank
- Put Well #7 on auto adjusting chlorine GPM

Miscellaneous:

- Inspected Ridgeview patchwork
- Frozen pipes: 45 Hawthorn Street 642 Beech Avenue 515 Laurel Blvd
- Fueled and cleaned trucks
- Equipment Operator and Water Repairer II assisted with salting township roads
- Prep Trenton Road for wet tap
- Replaced meter box lid at 9 Cochita Trail
- Checked meter at 122 Bobwhite Blvd
- Checked Sandra Drive for possible leak
- Installed primer bulb on blacktop cut saw