Water Division
Status Report
01/10/2018 – 01/16/2018

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- 23 Wildgeese (Emergency)
- 1 Scammel Drive
- 450 Dartmouth Ave
- 148 Arney's Mount Road
- 6 Pointville (Emergency)
- 11 Chestnut Avenue
- 18 N. Pemberton Road
- 200 Trenton Road
- Rancocas Lane
- 27 Briar Street
- 1412-1414 Junction

Water Meters:

- Completed meter readings in Books 9 & 10 (North Lakeshore Drive)
- Continued meter readings in Books 11 & 12 (North Lakeshore/Browns Mills)
- Final readings: 101 Oak Pines Blvd 243 Amherst Ave
  156 Canna Street

Water Turn Ons/Turn Offs:

- County Tank/PBM Rd
- Turned off 415 Snow Ave
- Turned off 537 Elm Avenue
- Turned off 14 Fort Dix Road
- Turned off 12 Fort Dix Road
- Turned off/on 109 Pin Oak
- Turned off 130 Trenton Rd
- Turned on 89 Wilkins Ave
- Turned off 124 Truro Street
- Turned off 47 Arbutus Street
- Turned on 17 Begonia Street
- Turned off 11 Ginsburg Lane
- Turned off 119 Almond Avenue
- Turned off 608 Berkeley Drive
- Turned off 21 Juliustown Road
- Turned off 120 Norfolk Street

Water Wells:

- Daily routine well checks morning/afternoon
- Replenished chemical supplies as needed
- Added chlorine and polyphosphate to wells as needed
- Water samples
- Changed chlorinator in Well #10
- Checked chlorine residual for the County system

Miscellaneous:

- Freeze Ups: 522 Laurel Blvd 250 Garden Ave
  6 Lobelia Avenue 610 June Road
  130 Trenton Road 21 Juliustown Road
- Repaired water main on Carnation Street
- Installed pressure relief valve on hydrant for County
- Repaired water leak at 1 Springfield Road
- Low pressure call at 140 Pemberton Browns Mills Road and 55 Pemberton Browns Mills
- Broken shut off at WLSD/Crocus