

**Water Division  
Status Report  
01/17/2018 – 01/23/2018**

**Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:**

- 217 Pemberton Browns Mills • 137 Vance Street • 50 Berkshire Street
- 91 Pemberton Browns Mills • 130 Trenton Road • Earlin Avenue
- 18 North Pemberton Road

**Water Meters:**

- Completed meter readings in Books 11 & 12 (North Lakeshore Drive/Browns Mills)
- Continued meter readings in Books 13 & 14 (East Lakeshore Drive)
- Final readings:

21 Berkshire Street	212 Coville Drive
212 Princeton Avenue	126 Dennis Avenue
519 Laurel Blvd	49 Wildgeese Circle

**Water Turn Ons/Turn Offs:**

- Turned off 1000 Belleview Blvd
- Turned on turned off and turned back on 47 Primrose Lane

**Water Wells:**

- Daily routine well checks morning/afternoon
- Replenished chemical supplies as needed
- Added chlorine and polyphosphate to wells as needed
- Water samples
- Troubleshoot county tank issue
- Flushed county tank.
- Performed 1" tap on county tank outgoing pipe – took coliform sample
- Static water tests at Well #1, Well #4 and Well #11

**Miscellaneous:**

- Updated meter location binders
- Performed maintenance on tools
- Cleaned water shop
- Unloaded supplies from Atlantic Plumbing
- Located shut off for 19 Wildgeese Circle – leak on customer's side
- Unloaded shipment of chlorine
- Checked 47 Primrose Lane for water main
- Completed cleaning and maintenance of eye wash stations
- Replaced meter at 245 Villanova Avenue
- Attempted to get new keys made for well gates
- Cleaned out shut off for 129 Newton