

**Water Division  
Status Report  
03/29/2017 – 04/04/2017**

**Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:**

- 231 Pemberton Blvd
- 500-600 PBM Road
- 26 Drexel St (Emergency)
- 234 LaFayette Avenue
- N. Pemberton Road
- 42 Lakehurst Road
- 16 Ivy St (Emergency)
- 36 Azalea Street
- 3 Tensaw Drive
- 150 Juliustown Rd

**Water Meters:**

- Completed meter readings in Books 5 & 6 (Trenton/West Lakeshore)
- Continued meter readings in Books 7, 8 & 8A (South Lakeshore)
- Final Readings: 241 LaFayette Dr., 131 Canna St., 119 Syringa St., 27 Verbena St., 607 Berkeley Dr., 335 Phillips Ave., 127 Pemberton Blvd., 11 Jefferson Ave., and 701 Hunter Blvd.,
- Read meters at Lakeshore Mobile Village and Pemberton Boro

**Water Turn On/Turn Off:**

- Turned on 11 Gleason Street
- Turned on American Legion ball field – turned back off – leaking inside building
- Turned on 103 Tensaw Drive

**Water Wells:**

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Water Samples
- Repaired leaking shaft at Well #13
- Radium and VOC samples at Well #11, Well #12 and Well #13

**Miscellaneous:**

- Completed annual fire hydrant flushing
- Unloaded shipment of chlorine
- Unloaded 30 meters from Atlantic Plumbing
- Water Repairer II had workers comp appointment
- Checked 102 Juliustown Road for leak
- Picked up supplies from Stevenson's
- Repaired chainsaws for DPW
- Repaired water service at 102 Juliustown Road
- Unloaded shipment of meter boxes
- Filled drains in water shop
- Installed meter box and meter at 1 Scammel Drive
- Removed battery from riding lawn mower and performed maintenance