

**Water Division  
Status Report  
05/09/2018 – 05/15/2018**

**Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:**

- 147 Wilton Way
- 130 Lester Street
- 25 Tensaw Drive
- 903 W Lakeshore (Emergency)
- 5 Holly Avenue
- 136 Adams Avenue
- 119 Morris (Emergency)
- 250 University (Emergency)
- 235 Snow Avenue
- 244 Purdue Avenue
- 88 Sepulga Drive
- 13 Elder (Emergency)

**Water Meters:**

- Completed meter readings in Books 17 & 18 (Boro/Country Lakes)
- Continued meter readings in Books 19 & 20 (Lakehurst Road)
- Final readings:           212 Coville Drive           503 Hanover Blvd  
                                  110 Hunter Blvd           11 Gleason Street
- Replaced meters:       327 Phillips Avenue       442 Lakehurst Road  
                                  613 Katherine Street
- Replaced broken meter box lid at 45 Fern Street

**Water Turn Ons/Turn Offs:**

- Turned on 32 Oxford Street

**Water Wells:**

- Daily routine well checks morning/afternoon
- Replenished chemical supplies as needed
- Added chlorine and polyphosphate to wells as needed
- Water samples
- Repaired chlorinator line and injector at Well #6
- Worked on chart at Well #12

**Miscellaneous:**

- Completed water main installation on Olive Avenue
- Spread stone with backhoe at Mirror Lake Beach parking lot
- Unloaded supplies from Atlantic Supply
- Re-stocked supplies on shelves and trailer
- Assembled fire hydrant for Olive Avenue
- Located shut off for 25 Tensaw Drive
- Sharpened chainsaw blades for DPW
- Picked up hoses and parts from Vermeer
- Water quality – low pressure call at 13 Elder Avenue, 50 Phillips Avenue and 219 Harvard Avenue
- Cleaned trucks

- Replaced meter box lid at 13 Clover Street
- Repaired and flushed line at 13 Elder Avenue
- Patched roads at Vine and Clubhouse
- Loaded hydrant and stone onto trailer
- Had trailer tire replaced
- Installed fire hydrant on Olive Avenue
- Charged line with chlorine and landscaped area on Olive Avenue