

Water Division Status Report **01/25/2017 – 01/31/2017**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- Dickens Street
- 1201 Belleview Blvd
- 360 Lakehurst Road
- 20 Pineview Drive
- 137 Juliustown Road
- Juliustown Road
- 40-42 Rancocas Lane
- 15 Broadway Street
- 32 Railroad Street
- 140 Auburn Avenue
- 23 Sepulga Drive
- 360 Lakehurst Road
- 115 Adams Avenue

Water Meters:

- Completed meter readings in Books 13 & 14 (East Lakeshore)
- Continued meter readings in Books 15 & 16 (Browns Mills)
- Re-read meter at 236 Eagle Avenue
- Final readings: 502 Berkeley Dr., 186 Daniels Ave., 111 Pemberton Blvd., 155 Daniels Ave., and 803 Hanover Blvd.

Water Turn Ons/Turn Offs:

- Turned off 210 Hargrove Avenue

Water Wells:

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Water Samples
- Prepped and painted wells
- Inspected generator at Well #2
- Replaced chlorinator and chlorine lines in Well #2
- Assisted DPW with roofs at wells
- Assisted ABS at Well #11
- Adjusted chlorinator and checked chlorine residual at Well #1
- Assisted George's Lock and Security at Wells
- Run Well #11 to waste
- Troubleshoot pre-lube issue at Well #11

Miscellaneous:

- Cleaned up Pine Avenue after leaks from previous night
- Restocked truck #62
- Installed meter box and meter at 11 Railroad
- Troubleshooting and maintenance on compressor
- Picked up boxes from Finance
- Assisted Deborah Hospital with valve location
- Jack hammered, dug up, located end of pipe and patched hole at Firehouse/Split Rock
- Repaired water line in shop
- Assisted resident at 2 Coville Drive with leak
- Located shut offs at 300 Junction Road and 278 Franklin Street
- Located shut offs in Oak Pines for future meter box installations